


**Government of Bihar**  
**Public Health Engineering Department**  
Water Quality Report


District:- Nawada

Sample Collected by:- Firm

Date of Sampling > 08-05-2028

| Sl. NO.                                           | Block  | Panchayat | Village | Name of Place           | Test Report |       |      |      |     |     |     |      |     |      | Source of water | Remarks |
|---------------------------------------------------|--------|-----------|---------|-------------------------|-------------|-------|------|------|-----|-----|-----|------|-----|------|-----------------|---------|
|                                                   |        |           |         |                         | pH          | Turb. | EC   | TDS  | TH  | Ca  | Mg  | Cl   | ALK | F    |                 |         |
| 1                                                 | 2      | 3         | 4       | 6                       | 7           | 8     | 9    | 10   | 11  | 12  | 13  | 14   | 15  | 16   | 17              | 18      |
| 1                                                 | Narhat | Babhaur   | Chatar  | Frontline Public School | 6.8         | 1.2   | 520  | 515  | 210 | 78  | 33  | 260  | 205 | 1.05 | Tap Water       |         |
| Desirable Limit* (IS:10600:2012)                  |        |           |         |                         | 6.5         | 1.0   | 500  | 500  | 200 | 75  | 30  | 250  | 200 | 1.0  |                 |         |
| Permissible Limit* in absence of alternate source |        |           |         |                         | 8.5         | 5.0   | 2000 | 2000 | 600 | 200 | 100 | 1000 | 600 | 1.5  |                 |         |

  
 Chemist  
 DLWTL, Nawada

  
 Assistant Engineer  
 P.H.Sub, Division, Nawada

  
 Executive Engineer  
 P.H.Division, Nawada

